

HYOSUNG HEAVY INDUSTRIES		INDUCTION MOTOR DATA SHEET		PROJECT No. 5881	
				MODEL No. 24TEFCFEB	
				L-SPEC No. DSML20954H	
SHEET 1 OF 1		CUSTOMER			
FOR INFORMATION		JOB NO.		ITEM No.	
SERVICE		SITE		QUANTITY	
GENERAL DATA			PERFORMANCE DATA		
FRAME No.		132M		OUTPUT 5.5 kW	
TYPE		TEFC		POLES 6 P	
ENCLOSURE		TE		ROTOR TYPE SQUIRREL CAGE	
COOLING METHOD		FC(IC411)		STARTING METHOD DIRECT ON LINE	
INSULATION CLASS		F CLASS		PHASE 3 PHASE	
TEMP. RISE AT FULL LOAD			FREQUENCY 60 Hz		
RES. METHOD		80 K (at S.F:1.0)		SPEED (AT FULL LOAD) 1180 r/min	
RATING		S1		PRIMARY	
LOCATION		INDOOR		VOLTAGE 220/380 V	
ALTITUDE		LESS THAN 1000 m		NO LOAD CURRENT 12.7/7.4 A	
HUMIDITY		LESS THAN 80 %		FULL LOAD CURRENT 22.3/12.9 A	
AMBIENT TEMP.		40 °C		LOCKED-ROTOR CURRENT 650 %	
EXPLOSION PROOF TYPE		N/A		EFFICIENCY	
MOUNTING		B3		AT 1/2 LOAD 88.0 %	
BEARING TYPE		ANTI-FRICTION		AT 3/4 LOAD 90.0 %	
NDE/DE BRG. No.		6207ZZ / 6208ZZ		AT FULL LOAD 91.0 %	
BRG. LUBRICATION		N/A		POWER FACTOR	
PROTECTION GRADE		IP55		AT 1/2 LOAD 56.0 %	
SERVICE FACTOR		1.15		AT 3/4 LOAD 66.0 %	
DRIVE		DIRECT COUPLED		AT FULL LOAD 71.0 %	
SHAFT			TORQUE		
EXTENSION		SINGLE		FULL LOAD 4.54 kg-m	
EXTERNAL THRUST		N/A		44.5 N-m	
NOISE LEVEL(MEAN VALUE AT 1m FROM MOTOR)			LOCKED ROTOR 250 %		
NO-LOAD		N/A		BREAKDOWN 300 %	
VIBRATION		N/A		MOTOR GD² 0.354 kg-m²	
NUMBER OF CONSECUTIVE STARTS		N/A		MAX LOAD GD² AT MOTOR SHAFT 18.2 kg-m²	
ROTATION(VIEWED FROM DE)		C.C.W		MOTOR APPROX. WEIGHT 85 kg	
ACCESSORIES (OPTIONAL)			PAINTING 0.5PB 3.2/4.4 (URETHANE)		
SUBMITTAL DRAWINGS					
TEMPERATURE DETECTOR			OUTLINE DIMENSION ES1AS40107		
WINDING NO			CONDUIT BOX & COVER ES1B100802		
TYPE -			SPEED-TORQUE & CURRENT CURVE DSML20954H		
BEARING NO			THERMAL LIMIT & TIME-CURRENT CURVE DSML20954H		
TYPE -			LOAD vs POWER FACTOR & EFFICIENCY DSML20954H		
SPACE HEATER NO			<REMARKS>		
RATING -			1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE.		
APPLICATION STANDARDS IEC60034-1, ISO 3746			2. PREMIUM EFFICIENCY TYPE MOTOR		
<NOTE>					
1. THESE DATA ARE ONLY DESIGN VALUES AND SHALL BE GUARANTEED WITH TOLERANCE OF APPLICATION STANDARD.			REV. NO DATE PREPARED CHECKED APPROVED		
2. EXCEPT FOR STATEMENTS SPECIFIED ON THIS SHEET, ANYTHING ELSE SHALL BE IN ACCORDANCE WITH MAKER STANDARD			1 2025-09-22 S.U.LEE J.H.CHA Y.J.PARK		
3. THE TEMPERATURE MEASURED AT BEARING HOUSING DOES NOT EXCEED 105°C.					

